



MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT
NARELA ZONE

No. DHO/NRZ/2025/D-659

Dated: 16/10/2025

SCHOOL HEALTH CERTIFICATE

Date of Inspection : 10.10.2025

1. Name of School : **QUEEN'S CONVENT SCHOOL**

2. Address : **SECTOR-25, ROHINI, DELHI-110085**

3. No. of Shifts : One Timing 07:55AM to 02:00 PM

Accommodation Provided

THE FLOOR AREA IN THE CLASSROOM IS SUFFICIENT.

THE CLASSES ARE WELL LIGHTED.

THE CLASSROOMS ARE WELL VENTILATED.

THE CLASSROOMS ARE KEPT NEAT AND CLEAN.

THE DRINKING WATER IS WATER TEST REPORT DJB LAB..

THE TOILET ARRANGEMENT IS SANITARY & HYGENIC AND SUFFICIENT IN NUMBER.

Remarks :

THIS CERTIFICATE DOES NOT INDICATE PERMISSIBILITY FROM LAND POINT OF VIEW.

The certificate is valid for one year from the date of issue.

The PRINCIPAL

QUEEN'S CONVENT SCHOOL
SECTOR-25, ROHINI, DELHI-110085

na
16/10/25
Dy. Health Officer
Narela Zone
Dy. Health Officer
Narela Zone

"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain S

safe



**DELHI JAL BOARD ;(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT HAIDERPUR,
DELHI-110085**



(ISO Certified 9001:2015)

**THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY**

Water samples collected from: - S1:-DJB Stored water; S2:- Drinking point in the premises of Queen's Convent School, A-Block, Sector-25, Rohini Delhi-110085 vide chalian no. 87 dated 01.07. 2025.

S. No.	PARAMETERS	UNITS	B.I.S.10500:2012		S1	S2
			Desirable	Permissible		
1.	Date of Collection	--	---	---	-----09.07.2025-----	
2.	Date of Analysis	--	---	---	-----11.07.2025-----	
3.	Colour	C.U.	5	15	3 C.U	2 C.U
4.	Odour	--	Agreeable		Agreeable	Agreeable
5.	Turbidity	N.T.U.	1.0	5.0	3.01	2.83
6.	p ^H value	--	6.5 to 8.5	N.R.	7.5	7.4
7.	Electrical Conductivity	µmhos/cm	---	---	260.0	256.0
8.	Total Dissolved Solid	(mg/l)	500	2000	169.0	166.4
* CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	(mg/l)	---	---	Nil	Nil
10.	Total Alkalinity	(mg/l)	200	600	72.0	68.0
11.	Total Hardness	(mg/l)	200	600	116.0	114.0
12.	Calcium Hardness	(mg/l)	---	---	80.0	78.0
13.	Magnesium Hardness	(mg/l)	---	---	36.0	36.0
14.	Calcium as Ca	(mg/l)	75	200	32.0	31.2
15.	Magnesium as mg	(mg/l)	30	100	8.64	8.64
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	ND	ND
17.	Nitrite -Nitrogen (N)	(mg/l)	---	---	ND	ND
18.	Nitrate NO ₃	(mg/l)	45	N.R.	4.01	3.28
19.	Sulphate (SO ₄)	(mg/l)	200	400	33.18	31.94
20.	Chloride (Cl)	(mg/l)	250	1000	22.0	20.0
21.	Iron (Fe)	(mg/l)	1.0	N.R.	0.03	0.02
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.32	0.28
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	ND	ND
24.	Residual Chlorine	(mg/l)	0.2	1.0	0.75	0.50
* BACTERIOLOGICAL EXAMINATION						
25.	Coli form per 100 ml at 37 ^o c	MPN/100 mL	0		0	0

Remarks: On the basis of tested parameters, water samples 'S1' & 'S2' confirm to drinking water specification IS.10500:2012 and may be used for drinking purpose.

Asstt. Chemist
11/2/25

Chemist/Bacteriologist

A.C.W.A.

C. W. A. (W&S)-II